

FUSION BONDED EPOXY COATED C153 DUCTILE IRON PUSH-ON FITTINGS

FUSION BONDED EPOXY COATED C153 DUCTILE IRON PUSH-ON FITTINGS

BASIC SPECIFICATIONS

- SIZES:**
- 4" - 24"
- MATERIAL:**
- Ductile Iron ASTM A536, Grade 65-45-12, 60-42-10 or 70-50-05.
- PRESSURE:**
- 350 PSI Water Working Pressure 4" - 24"
- TESTING:**
- In accordance with ANSI/AWWA C153/A21.53.
 - In accordance with UL - FM requirement.
 - All fittings are hydrostatically tested in accordance with SIGMA Quality Management Standard.
 - All fittings are heat coded to ensure traceability and verification of metallurgical properties in accordance with SIGMA Quality Management Standards.
- LAYING LENGTH:**
- Short body design - straight section of body deleted to provide a compact and lighter fitting without reducing strength or flow characteristics.
 - In accordance with ANSI/AWWA C153/A21.53.
- DEFLECTION:**
- Up to 5 degrees, in accordance with TYTON JOINT bell design
- COATING:**
- SIGMA FBE Coated Fittings are NSF61 and Annex G approved for potable water applications. The Epoxy Coated Fittings meet or exceed ANSI/AWWA C116/A21.16 and C550 standards (Protective Fusion-Bonded Epoxy Coatings for the Interior and Exterior surfaces of Ductile-Iron and Gray-Iron fittings for water supply service).
 - FBE coated fittings of SIGMA are available from 2" to 48" in accordance with ANSI/AWWA C153/A21.53.
- GASKETS:**
- Dual hardness SBR in accordance with ANSI/AWWA C111/A21.11.
- JOINT:**
- TYTON JOINT® push-on bell joint design, manufactured by SIGMA under license from the United States Pipe and Foundry Company.
- APPROVALS:**
- 4"-12" Underwriters Laboratories listed and Factory Mutual Approved.
- STANDARDS:**
- Certified to NSF61 Standard including Annex G & 372.
 - ANSI/AWWA C153/A21.53 for Compact Ductile Iron Fittings 2"-64" for water and other liquids.
- INSTALLATION:**
- Per ANSI/AWWA C600 and C111 using DIP conforming to C150/C151 and PVC pipe conforming to C900/C905.

